

FREQUENTLY ASKED QUESTIONS

1. Is 5" K style aluminum gutter acceptable for this project?

5" K style .032 aluminum gutter is acceptable.

2. Are 3"x4" downspouts acceptable for this project?

3"x4" downspouts are acceptable, same as existing.

3. Is PAC-750 soffit acceptable to use on this project?

PAC-750 .032 soffit is acceptable.

4. Does any of the soffit require venting?

Vented soffit will be required adjacent to roof areas which have open attic and vented roof.

5. Will cameras, lights, junction boxes, and signs be relocated prior to work occurring?

Coordination will occur with Village staff depending on the specific situation. This may include but not limited to the removal of device and necessary access to connection points or reinstallation by Village of Homer Glen staff.

6. Please confirm old wood soffit & fascia is to remain?

Existing wood soffit & fascia is to remain.

7. Is the rake metal drip edge to remain?

The rake metal drip edge is to remain.

8. Are windows, siding, posts getting aluminum trim?

Windows, siding, and posts are not getting aluminum trim.

9. Are entrance way ceilings getting soffit?

Entrance way ceilings are getting new aluminum soffit.